

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1483:148 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410
Contact: Brad Miller (888) 649-9827 Fax (203) 699-3108

DESIGN: Models "EST" MG1-V15, -V30, V60, V75, -V110; *MG1F-V15, *-V30, *-V60, *-V75, *V110; MG1R-V15, -V30, V60, -75, -V110; *MG1RF-V15, *-V30, *-V60, *-V75 and *-V110 single gang strobe lights. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 24-30 VDC
Candela: 15cd, 30cd, 60cd, 75cd,*110cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, EST, Edwards Systems Technology or Edwards, model number, electrical/candela rating and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control units. For indoor use and wall mount only.

XLF: 7125-1388:232

*Rev. 08-13-2002 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 18, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager